

***A World of Cultures  
United in Learning***



**OHLONE**  
**COLLEGE**

**ADDENDUM No. 2**

*Issued October 13, 2009*

**BID 465-09**

**Performance Hall Chiller Plant Upgrade**

**OHLONE COMMUNITY COLLEGE DISTRICT  
ADDENDUM No. 2  
for  
BID 465-09  
Performance Hall Chiller Plant Upgrade**

**TABLE OF CONTENTS**

1. Changes to Specifications and Drawings

**OHLONE COMMUNITY COLLEGE DISTRICT**  
**ADDENDUM No. 2**  
**for**  
**BID 465-09**  
**Performance Hall Chiller Plant Upgrade**

The following additions, changes, clarifications, or deletions are being made to the bid documents for Bid 465-09, Performance Hall Chiller Plant Upgrade:

**CHANGES TO THE SPECIFICATIONS:**

**Section 15627 –Centrifugal Water Chillers – Section 2.04 Evaporator- Part A.**

Delete “Tubes shall be a minimum of 0.035 inch wall thickness” and replace with “Tubes shall be a minimum of 0.025 inch wall thickness”.

**Section 15627 –Centrifugal Water Chillers – Section 2.05 Condensers- Part A.**

Add the following; “Tubes shall be a minimum of 0.025 inch wall thickness”

**Section 15627 –Centrifugal Water Chillers – Section 2.05 Condensers- Part C.**

Delete; “ Provide marine type water boxes, machine welded to heat exchanger with tapped drain and vent connection, and flanged or mechanical joint connections arranged to permit inspection of tubes from either end without disturbing refrigerant and removable without disturbing water piping.”

Replace with, “Provide standard evaporator and condenser heads with tapped drain and vent connection, and flanged or mechanical joint connections.”

**CHANGES TO THE DRAWINGS:**

**Sheet MI 5.3**

ADD TO THE FOLLOWING SHEET NOTE TO SHEET MI-5.3: “EXISTING CONTROLS SYSTEM IS I-NET 2000 MADE BY CSI WHICH IS NOW T.A.C.”

**Sheet M 1.1**

ON SHEET M-1.1 DELETE AND REPLACE GENERAL SHEET NOTE A WITH THE FOLLOWING, “RECOVER/RECYCLE CHILLER R-22 REFRIGERANT IN ACCORDANCE WITH THE LATEST PROVISIONS OF THE CLEAN AIR ACT.”

This addendum shall become a part of the Contract Documents for Ohlone Community College District Bid 465-09. All other terms, specifications, and conditions remain the same. The bidder is responsible for transmitting this information to all affected subcontractors and suppliers prior to the closing of bids. Bidder shall acknowledge receipt of this addendum on the bid form.

END OF ADDENDUM NO. 2